

Testing & Tagging Intervals of Electrical Leads & Equipment Schedule

EQUIPMENT & ENVIRONMENT	CLASS 1 EARTH PROTECTED	CLASS 2 DOUBLE INSULATED	EXTENSION CORDS & LEADS
Factories, Workshops, Service Centres, Work Places for Repair Manufacturing, Assembly, Maintenance or Fabrication	6 months	12 months	6 months
Laboratories, Health Care & Educational Work Places, Tea Rooms and Office Kitchens	12 months	12 months	12 months
Office Areas (Hostile Use - abusive, flexing)	12 months	12 months	12 months
Office Areas (Normal Use – not hostile, abusive or flexing)	5 years	5 years	5 years
Hire Equipment	Monthly	Monthly	Monthly
Equipment that has been serviced, repaired or second hand	When 1 st put into use Then per schedule	When 1 st put into use Then per schedule	When 1 st put into use Then per schedule
Commercial Cleaning	6 months	12 months	12 months
Residential institutions, hotels, boarding houses, hospitals, motels, hostels etc.	2 years	2 years	2 years
Building & Construction use	Commercial – Monthly Domestic – 3 months Amenities – 3 months	Commercial – Monthly Domestic – 3 months Amenities – 3 months	Commercial – Monthly Domestic – 3 months Amenities – 3 months

Ref: Australian Standard 3760, OHS Regulation 2001 and WorkCover NSW Code of Practice (Electrical)